

Hydrant Flow Test Report

Test Date 4/4/2019

Test Time 9:30 a.m.

Location

117 Louise St
Elgin, TX

Tested by

Capital Hydrant LLC
Rob Stephenson

Notes

Test: 813 Lexington St - 1981 AD B62B
30.359467/ -97.366780
Flow: Louise/ Lexington - 2008 EJIW
30.358525/ -97.367591

Read Hydrant

62 psi **static pressure**
52 psi **residual pressure**
hydrant elevation

Flow Hydrant(s)

Outlet	Elev	Size	C	Pitot Pressure	Flow
#1		2.5	.899	18	711 gpm

Flow Graph

